

WTCI-50-P

W-4412 - DELOITTE HASKINS & SELLS -
1 WTC - 97th FLOOR - DEMOLITION OF
EXISTING OFFICE SPACE

REVIEW STATUS

[illegible]

THE PORT AUTHORITY OF NEW YORK & NEW JERSEY

M E M O R A N D U M

To: Mr. A. Vaccaro, Acting General Manager,
Planning, Design & Construction, WT&ED
From: Ennala Ramabhushanam
Date: November 16, 1989
Subject: WTC - ALTERATION APPLICATION #W-4412 - DELOITTE, HASKINS, & SELLS -
1 WTC, 97TH FLOOR - DEMOLITION OF EXISTING OFFICE SPACE
Reference: Review Request dated 11/2/89
Copy To: T. O'Connor L. Menno Job Folder
 R. Wegel Chrono Folder

A review of the material submitted with the referenced request for the subject application has been made.


It is recommended that approval to proceed with construction be given subject to the submission of the items listed below being revised in accordance with the one (1) requirement listed on the attached rider.

Drawings:

REMARKS: 1) Following drawings are recommended for approval.

D-1	issued	10/30/89
D-2	issued	10/30/89
H97-D-1	undated	

2) This memorandum was transmitted to the Facility via OA on November 16, 1989.

for - 
Ennala Ramabhushanam, P.E.
Manager
Quality Assurance Division

FD-B/dm
att.

RIDER

ALTERATION APPLICATION #W-4412

HVAC

1. Dwg. H97-D-1, Demolition Note NO. 15. Revise last paragraph of the note to require that air filters shall either be Class 1 or Class 2. See N.Y.C. Building Code, RS 13-1, Section 2-4.1.1.

111689

11/3

TENANT ALTERATION REVIEW REQUEST

X	CHECK APPLICABLE ROUTING	ROOM NO.	Description of Work: DEMOLITION OF EXISTING OFFICE SPACE. Work includes - Demo - of Arch. Partitions, Elec, Tele, Ceiling & H.V.A.C.	FACILITY ONE WTC
	✓ P. COOPER	51-N		APPLICANT'S NAME DELOITTE HASKINS
	✓ QUALITY ASSURANCE REV.	745		APPLICATION NO. 4412
	✓ C. SEMAH	745		DRAWING NO(S). 3
	✓ G. DALY	745		DATE 11 12 1989
	✓ M. GLAVICIC	745		
			You are requested to review the attached applications and forward your comments to:	
			Attached are revised drawings. Please review	
			Org. Unit	Contact
			1 Joseph Ruiz	1745
				Rm. No.
				Ext.
				466 8668
				Arch/DESIGNER
			NOT LATER THAN	10-20-89
			If no reply is received by above date, your concurrence will be assumed unless arrangements have been made for additional time.	

DELOITTE, HASKINS & SELLS
TAA# 4412, Contract # WTC-591.861

DWG NAME

DATE

D-1 - Partition/Elec. & Telep. Demo PL. 10/30/89
D-2 - Reflected Ceiling Demo, PL. 10/30/89
H97-D-1 HVAC DEMO. Plan 10/31/89

cc: J. Napolitano, L. Menno,
Estimated Price \$ 257,000

THE PORT AUTHORITY OF N.Y. & N.J.
TENANT CONSTRUCTION REVIEW UNIT
RECEIVED
NOV 03 1989
W-4412
ALTERATION APPLICATION

Signature: *Joseph Napolitano* Title: *for L. Menno* Date: *11/3*